

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman Garh Road in Water works Near Bye pass, Abohar
bwtlabh@gmail.com

To,

SDE Sub-Division Khuian Sarwar, W/S & Sanitation Abohar
IMPERIAL INTERNATIONAL SCHOOL, KHUIAN SARWAR


No.: Abohar/2627/00017 Dated : 17/04/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. LETTER NO.340 Dated: 15/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 15/04/2026. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Abohar

D/A : Test Report



Authorized Signatory
For, Block Water Testing Laboratory
Abohar

BLOCK WATER TESTING LABORATORY, ABOHAR


Hanuman Garh Road in Water works Near Bye pass, Abohar
bwtlabh@gmail.com

TEST REPORT						
Name & Address of Customer : SDE Sub-Division Khuian Sarwar,W/S & Sanitation Abohar IMPERIAL INTERNATIONAL SCHOOL,KHUIAN SARWAR			Customer Reference No.		No : LETTER NO.340 Dated : 15/04/2026	
			Sample Submitted by		SANDEEP KUMAR	
			Date of Sample Receipt		15/04/2026	
			Analysis Starting Date		16/04/2026	
			Analysis completion Date		17/04/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:				Sample Type :		Water
Test Report No.:		Abohar/2627/00017		Date of Issue :		17/04/2026
Registration no.:		Abohar/REG2627/00087		Condition of Sample :		Sealed
Collection Point:		Distribution Point(Near Bus stand,School,Gurudwara,etc)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		IMPERIAL INTERNATIONAL SCHOOL(TAP WATER) / NA
Village :		Khuian Sarwar		Habitation :		Khuian Sarwar
Block:		Khuian Sarwar		District :		Fazilka
Latitude :		30.07101		Longitude:		74.04002
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.16@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	405	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.4	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	172	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	260	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	88	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	10	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	64	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Ashish Kumar
Sr. Chemist
Authorized Signatory
For,Block Water Testing Laboratory
Abohar

----- End of the Test Report -----